



## Re-use of Blow-down Colling Tower

### Savings at you Hand

- Reduction of fresh water consumption
- Reduction of Waste Water Discharge Costs
- Water quality assurance
- Return on investment less than 1 year

#### Challenge

Our customer is a big food & beverage company, located in Portugal, with 9 evaporative condensers, used to refrigerated 15 cold compressors.

The consumption of new water in these circuits reaches an annual average of 70 m<sup>3</sup> / h, with a combined blow-down flow of 15 m<sup>3</sup> / h.

The water used to compensate refrigeration comes from the municipal network, with a cost of 2,10 €/m<sup>3</sup>.

Likewise, the treatment cost of the effluent generated in the WWTP is 0,21 €/m<sup>3</sup>, plus 0.75 €/m<sup>3</sup> of discharge cost to the municipal collector.

The client determined the objectives of this study to reduce operation costs.

The table below shows the blow-down water quality .

| Parameter              | Units                  | Value |
|------------------------|------------------------|-------|
| Turbidity              | NTU                    | 12    |
| Micro-organisms at 37° | Ufc/ml                 | > 300 |
| TSS                    | mg/l                   | 22    |
| Conductivity           | µS/cm                  | 1 100 |
| Phosphates             | mg/l                   | 4,5   |
| Total Hardness         | mg/l CaCO <sub>3</sub> | 495   |
| Iron                   | mg/l                   | 0,83  |
| Chlorine               | mg/l                   | 158   |
| Total Alkalinity       | mg/l CaCO <sub>3</sub> | 147   |
| Salt Density Index     | ---                    | > 4   |
| pH                     | Esc Sorensen           | 8.1   |

#### Initial Solution

GreatWater E & S carried out a test with a pilot unit, consisting of PVDF capillary type ultrafiltration membranes. This is a testing unit that GreatWater E & S has to rent.

A pilot was constructed with a HydraCap 40Max type membrane with a porosity of 0.08 µm and a filtration area of 52 m<sup>2</sup>.

A bag filter having a porosity of 100 µm was also placed in the ultrafiltration inlet.

We used a pump with a capacity of 1000 l / h at 20 mca.

A blowing system of 15 Nm<sup>3</sup> / h at 0.5 bar was considered for the air delivery in the cleaning process.

A dosing rack with a clean water tank was also installed, performing daily membrane cleaning with hypochlorite every 7 hours, weekly with caustic soda and citric acid, in counter flow, daily.

#### Results — First:

| Parameter              | Units                  | Value |
|------------------------|------------------------|-------|
| Turbidity              | NTU                    | 0     |
| Micro-organisms at 37° | Ufc/ml                 | 0     |
| TSS                    | mg/l                   | 0     |
| Conductivity           | µS/cm                  | 1 100 |
| Phosphates             | mg/l                   | 4,5   |
| Total Hardness         | mg/l CaCO <sub>3</sub> | 495   |
| Iron                   | mg/l                   | 0,83  |
| Chlorine               | mg/l                   | 158   |
| Total Alkalinity       | mg/l CaCO <sub>3</sub> | 147   |
| Salt Density Index     | ---                    | < 3   |
| pH                     | Esc Sorensen           | 8.1   |

The Ultra-filtration process allowed to verify that the purge parameters can be adjusted, in order to allow their reuse.

Note that Ultra-Filtration membranes remove 99% of the viruses and bacteria present in the water.

Additionally, in order to verify the installation's operating limit, an activated carbon filter was added to remove free chlorine and a reverse osmosis unit in order to enhance the reuse of this water again in the cooling tower make-up.

In this way, we intend to be able to reuse 60% of the blow-down, reducing the waste to be sent to the WWTP to be only 6 m<sup>3</sup> / h.

Compensation of towers in this way would be reduced by 9 m<sup>3</sup> / h, dropping from 70 to 61 m<sup>3</sup> / h, minus 13%.





## Re-use of Blow-down Colling Tower

### Savings at you Hand

#### Final Results

From the test, it was possible to reach 75% of conversion on the reverse osmosis unit.

Thus, we obtained a water produced by the reverse osmosis unit, which is described below .

| Parameter              | Units                  | Value |
|------------------------|------------------------|-------|
| Turbidity              | NTU                    | 0     |
| Micro-organisms at 37º | Ufc/ml                 | 0     |
| TSS                    | mg/l                   | 0     |
| Conductivity           | µS/cm                  | 44    |
| Phosphates             | mg/l                   | 0,15  |
| Total Hardness         | mg/l CaCO <sub>3</sub> | 1,2   |
| Iron                   | mg/l                   | 0,02  |
| Chlorine               | mg/l                   | 4,5   |
| Total Alkalinity       | mg/l CaCO <sub>3</sub> | 7     |
| pH                     | Esc Sorensen           | 6,2   |

#### Comments

It was possible to achieve a higher than expected degree of operation in terms of conversion of the reverse osmosis unit .

Thus, the rejection of the following unit for the WWTP was 3,75 m<sup>3</sup>/h, being reused in the make-up of the cooling towers 11,25 m<sup>3</sup>/h, corresponding to a reduction of fresh water consumption of 16% .

The operation of the unit presented a regular trend without any changes, having worked for 30 consecutive days without any kind of interruption .

All the water produced was added directly into the basin of the cooling tower, representing in this test a reduction of fresh water of 8 100 m<sup>3</sup> .

#### Benefits and Economical Return

By annualizing, we can determine the costs in water, treatment and discharge of the effluent generated by the blow-down of the towers, which are summarized in the following table .

|                                 |                      |                              |
|---------------------------------|----------------------|------------------------------|
| Make-Up before                  | m <sup>3</sup> /year | 571 200                      |
| Blown-dow before                | m <sup>3</sup> /year | 122 400                      |
| Annualized Make-Up              | m <sup>3</sup> /year | 475 320                      |
| Annualized Blow-down            | m <sup>3</sup> /year | 30 600                       |
| Fresh Water Savings             | m <sup>3</sup> /year | 95 880                       |
| WWTP reduction                  | m <sup>3</sup> /year | 91 800                       |
| <i>Fresh Water Savings</i>      | €/year               | 201.348,00 €                 |
| <i>WWTP savings</i>             | €/year               | 88.128,00 €                  |
| <i>Total Annualized Savings</i> | €/year               | 289.476,00 €                 |
| <b>Return In Investment</b>     |                      |                              |
| <b>ROI / ROE</b>                | <b>11,2 meses</b>    | <b>187 680 m<sup>3</sup></b> |

